

Model Demonstration and Training

New Providence, Eleuthera & Exuma Islands



energynautics
solutions for sustainable development

Ankit Jotwani

Nis Martensen

Energynautics GmbH

11.05.2023

Based in Darmstadt, Germany

Services by Energynautics

- Grid Studies
- Smart Grid Development
- Power Generating Unit Modelling
- Grid Code Development
- Measurement Campaigns
- Capacity Building
- Conference Planning



AGENDA





energynautics
solutions for sustainable development

- **Project Objective**
- **Methodology and Case Matrix**
- **Power System Model Development**
- **Intro to ETAP**
- **Study Organization**
- **Load Flow**
- **Transient Stability**

Project Objective

Energynautics was commissioned to undertake a power system stability study for islands in Bahamas – New Providence, Eleuthera and Exuma to assess their future readiness for renewable integration



Methodology (Phase I)



energynautics
solutions for sustainable development

Data Collection and Analysis

Energy resources, renewable targets, existing SLD, expansion plans, unit parameters, cost and merit order

Capacity optimization in HOMER

Estimating best mix of generating capacities to meet the targets and choosing scenarios for analysis

Modelling in ETAP

Updating the SLD with current state, incorporating future expansions, selecting appropriate dynamic models, setting the cases

Stability analysis in ETAP


Generator dispatch, reserves, voltage violations, steady state simulations, contingency analysis

Scenario	Cases	PV instantaneous penetration
2020 (0% RE)	Peak Load (evening) High PV (mid-day) Light Load (night)	0 % 0 % 0 %
2023 (5.3% RE)	Peak Load High PV Light Load	10 % (BESS) 30 % 0 %
20230 (30% RE)	Peak Load High Floating PV High Distributed PV Light Load	8 % (BESS) 75 % 75 % 0 %

Possible Pathways

Selected Cases

Case Matrix (Phase I)



Power System Development

Study Phase I (NP)

	2020	2023	2030
Synchronous Generator	480 MW 20 Generators	500 MW 26 Generators	500 MW 26 Generators
Commercial PV	0.9 MW 1 PV	25 MW 16 PVs	115 MW / 55 MW 16 PVs
Residential PV	0	0	90 MW / 30 MW 16 PVs
Utility PV	0	30 MW 1 plant	30 MW / 150 MW 1 plant
Battery	0	25 MW 1 BESS	25 MW 1 BESS

Study Phase II (Exuma)

	2023	2026	2030
Synchronous Generator	(17.6 + 6) MW 4 main + 6 ren.	(17.6 + 6) MW 4 main + 6 ren.	(17.6 + 6) MW 4 main + 6 ren.
Commercial PV	4 MW 3 PVs	6 MW 4 PVs	9 MW 4 PVs
Residential PV	0	3 MW 3 PVs	6 MW 3 PVs
Battery	2 MW 1 BESS	2 MW 1 BESS	3 MW 1 BESS

Synchronous Generator	30.7 MW 10 Generators	30.7 MW 10 Generators	30.7 MW 10 Generators
Commercial PV	6 MW 4 PVs	10 MW 4 PVs	16 MW 4 PVs
Residential PV	0	4 MW 4 PVs	8 MW 4 PVs
Battery	0	2 MW 1 BESS	4 MW 1 BESS

Study Phase II (Eleuthera)

Static Simulations

- Model Organization
- Running Load Flow
- Power Flow Results
- Changing Power Flow Model


Dynamic Simulations

- Running dynamic simulations
- Simulation Results
- Changing models




energynautics
solutions for sustainable development

Introduction to ETAP: Interface




Introduction to ETAP: NP Example

Revision



- No two revisions can be activated at same time
- Out of service for an element a revision

Study Case



Synchronous Generator Editor - G6

Hamonic	Protection	Reliability	Fuel Cost	Time Domain	O and M	Remarks	Comment	
Info	Rating	Capability	Imp/Model	Grounding	Inertia	Exciter	Governor	PSS
13.8 kV 18.8 MW Voltage Control								
Rating								
MW	kV	% PF	MVA	% Eff.	Poles			
18.8	13.8	80	23.5	97.9	14			
% of Bus Nom. kV			FLA	RPM				
100			983.2	514				
Gen. Category								
1	Design	100	0		19.957	-7		
2	Normal	100	0		19.957	-7		
3	Peak Load	103.5	15.7		15.997	-7		
4	Light Load	103.5	15.7		15.997	-7		
5	High PV	103.5	15.7		15.997	-7		
6	Startup	100	0		19.957	-7		
Prime Mover Rating								
Continuous			Peak					
HP	MW	HP	MW					
25211.2	18.8	25211.2	18.8					
Mvar Limits								
<input checked="" type="radio"/> Capability Curve				Peak Mvar				
<input type="radio"/> User-Defined				18.037				
Operating Values								
% V		Vangle	MW	Mvar				
103.5		0	15.7	3.599				

OK Cancel

Load flow and
transient stability
study cases differ!

Intro to ETAP: Wizards

Scenario Wizard

Scenario ID: 20_LF_LL [New] [Copy] [Delete] [Run]

Parameters

System: Network Analysis Study Mode: Load Flow

Presentation: line2 Study Type: Load Flow

[Base] [20_LL_LF]

[20_LL] [20_LL_rep]

☐ Get Online Data ☒ Real-Time ☐ Archived ☐ Archive for OTS
☐ RT Config ☐ Archived Config

Preferences/Ini File: OutputToSQLite=1 [Edit]

"What-If" Studies [Edit] [Select]

Project and Library

☒ ETAP Default Library C:\ETAP 2102\lib\etapLib2100.lib

☐ Project Specific Library C:\ETAP 2102\lib\etapLib2100.lib

Project File: C:\Users\workshop\Desktop\Ankit\etap\BPL_ETAP_0211

Remarks

☐ Output Data Comparison [Compare] [View] [Edit]

Benchmark File

< 20_LF_LL > [Help] [OK] [Cancel]

Revision

Study Case

Name of
report/db file

Batch running
simulations via
Study and Project
Wizard

Study Wizard

Study Macro ID: 2020_transient_simulation [New] [Copy] [Delete] [Run]

☐ Send LF Results to File [Clear] [Browse] [View]

Parameters

Order	Active	Scenario	Pause
1	<input checked="" type="checkbox"/>	20_TS_PL_e1	<input type="checkbox"/>
2	<input checked="" type="checkbox"/>	20_TS_PL_e4a	<input type="checkbox"/>
3	<input type="checkbox"/>	20_TS_PL_e4b	<input type="checkbox"/>
4	<input checked="" type="checkbox"/>	20_TS_PL_e5a	<input type="checkbox"/>
5	<input type="checkbox"/>	20_TS_PL_e5b	<input type="checkbox"/>
6	<input checked="" type="checkbox"/>	20_TS_LL_e1	<input type="checkbox"/>
7	<input checked="" type="checkbox"/>	20_TS_LL_e4a	<input type="checkbox"/>

[Add] [Insert] [Delete] [View]

Comparison File

Global Summary (Pass/Fail) Report

C:\Users\workshop\AppData\Roaming\OTINETAPS\21.0.2\GlobalSummaryReport.sdf [Browse] [View]


[Clear]

< 2020_transient_simulation > [Help] [OK] [Cancel]

2020_transient_simulation
2023_transient_simulation
2030_transient_simulation
LF macro

To export data in
SQLite db
file

Study organization



Load Flow




Running Load Flow

Activating alert window
Report Manager

Load Flow Analyser

Case names as per
report names



Ref.	Select	Reports
2	<input checked="" type="checkbox"/>	23_PL_LF
3	<input type="checkbox"/>	23_PL_LF
4	<input type="checkbox"/>	23_PL_LF
5	<input type="checkbox"/>	23_PL_LF
6	<input type="checkbox"/>	23_PL_LF
7	<input type="checkbox"/>	23_PL_LF
8	<input type="checkbox"/>	23_PL_LF
9	<input type="checkbox"/>	23_PL_LF
10	<input type="checkbox"/>	23_PL_LF
11	<input type="checkbox"/>	23_PL_LF
12	<input type="checkbox"/>	23_PL_LF
13	<input type="checkbox"/>	23_PL_LF
14	<input type="checkbox"/>	23_PL_LF
15	<input type="checkbox"/>	23_PL_LF
16	<input type="checkbox"/>	23_PL_LF
17	<input type="checkbox"/>	23_PL_LF
18	<input type="checkbox"/>	23_PL_LF
19	<input type="checkbox"/>	23_PL_LF
20	<input type="checkbox"/>	23_PL_LF
21	<input type="checkbox"/>	23_PL_LF
22	<input type="checkbox"/>	23_PL_LF
23	<input type="checkbox"/>	23_PL_LF
24	<input type="checkbox"/>	23_PL_LF

Load flow analyser

Provides overview
of results for buses,
branches, sources,
loads

Source load flow
results

	ID	MW	Mvar	% PF	% Generation
1	BESS_system	25	7.5	95.78	100
2	G1	15.7	45.692	32.5	83.5
3	G2	15.7	0.0366	100	83.5
4	G3	15.7	0.0366	100	83.5
5	G4	15.7	0.0366	100	83.5
6	G5	15.7	0.0366	100	83.5
7	G6	15.7	0.0366	100	83.5
8	G7	15.7	0.0366	100	83.5
9	G8	9.823	6.538	83.25	52.2
10	G9	9.823	6.538	83.25	52.2
11	G10	15.7	6.538	92.32	83.5
12	G11	15.7	6.538	92.32	83.5
13	G12	15.7	6.538	92.32	83.5
14	G13	15.7	6.538	92.32	83.5
15	GT1R	22	32.893	55.59	63.8
16	SUN01	4.1	3.075	80	100
17	SUN02	4.1	3.075	80	100

Load flow reports

Load Flow Report Manager

Complete Input Result Summary

High Voltage DC Link
Impedance
Line Compensation
Line Coupling
Reactor
SVC
Switched Capacitor
Transformer
UPS
VFD

Viewer
PDF
MS Word
Rich Text Format
MS Excel
Set As Default


Output Report Name
23_PL_LF

Path
C:\Users\workshop\Desktop\Ankit\etap\BPL_ETAP_02112022\ETAP_BPL_02112022

Help OK Cancel

2-Winding Transformer Input Data

Transformer		Rating					Z Variation			% Tap Setting		Adjusted	Phase Shift	
ID	Phase	MVA	Prim. kV	Sec. kV	% Z1	X1/R1	+ 5%	- 5%	% Tol.	Prim.	Sec.	% Z	Type	Angle
ALB1-T1	3-Phase	15.000	33.000	11.000	8.26	18.60	0	0	0	0	0	8.2600	Dyn	0.000
ALB1-T2	3-Phase	15.000	33.000	11.000	8.23	18.60	0	0	0	0	0	8.2300	Dyn	0.000
BESS01-TX	3-Phase	31.000	33.000	13.800	9.70	20.00	0	0	0	0	0	9.7000	YNd	0.000
DA9-XF	3-Phase	35.000	34.500	11.000	10.16	13.00	0	0	0	0	0	10.1600	YNd	0.000
DA10-XF	3-Phase	35.000	34.500	11.000	10.20	13.00	0	0	0	0	0	10.2000	YNd	0.000
DA12-XF	3-Phase	42.000	34.500	11.000	8.84	29.50	0	0	0	0	0	8.8400	YNd	0.000



LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
1 VENETW	33.000	93.732	-9.2	0.000	0.000	1.503	0.640	VENETW-T1_Bus	0.000	0.000	0.0	0.0	
								VENETW-T1_Bus2	0.000	0.000	0.0	0.0	
								703 WIND33B	-1.503	-0.640	30.5	92.0	
301 CPPS SUBB-A	33.000	102.091	-3.9	0.000	0.000	11.892	5.066	Bus40	-32.548	-10.222	584.6	95.4	
								Bus48	-32.548	-10.222	584.6	95.4	
								Bus49	-44.367	-15.253	804.0	94.6	
								Bus47	-27.384	-10.831	504.7	93.0	
								Bus50	-27.384	-10.831	504.7	93.0	

Transient Stability

Why needed?: Concerned with studying the system response to severe transient disturbances such as fault on transmission facilities, loss of generation or loss of load. Dynamic RMS simulations are conducted for each event to assess **frequency stability**, **dynamic voltage stability** and **rotor angle stability**


Choosing Dynamic Models: appropriate model with the right functionalities for these components. IEEE standards for choosing excitation, governor models, WECC2/IEC for renewables

Setting right parameters for models: Realistic set of parameters to mimic the actual component response, validation necessary!




Running transient simulations

For plotting the results, can also be plotted in SLD directly




ETAP UDM Models in Use

Synchronous generator




Governor: GGOV1, DEGOV1
Exciter: AC4A, AC7B, AC8B

Residential PV




Unit: PVD1

Commercial and Utility PV



Unit: WECC2ndType4AB
Plant: REPC_A


Battery



Model: BESS_Model
Plant: REPC_A



UDM Graphic Logic Editor


7



UDM models vs built-in?

- Built-in WECC models are 1st generation models
- Control behavior of built-in models cannot be altered – grid code dependent
- UDM models allow for easy debuggability and allow plotting options for internal control signals
- Plant controller can be used to set reference set-points for multiple UDM models
- Reference set-point changes possible during the simulation

Example Stability Results (2020)



No secondary reserve

Secondary reserve wasn't modelled.
Governor droop acts in to stabilize
frequency after the event

Loss of DA12


Outage of generator DA12
producing 25 MW power. Plots show
mechanical power of remaining
generators

System Details

Scenario: Peak Load
Total Generation: 245 MW
Renewables: 0.9 MW

System reaches a stable
state with no frequency or
voltage violations after the
event. Protection limits not
triggered.

Example Stability Results (2023)



Fault and loss of line

A low voltage fault is followed by removal of 132 kV line.

System Details

Scenario: High PV

Total Generation: 175 MW


Renewables: 58 MW

Battery: -25 MW (Charging)

Relative Rotor Angles


Plots show no angular instability

Example Stability Results PV (2023)



Utility PV and Battery Plot. Battery is charging before the event

Commercial PVs active and reactive power. The PVs provide both frequency and fault ride-through support



Bus voltage and frequency profiles

System reaches stable state, no frequency or voltage violations. Converter units contribute to fault support.

Example Stability Results (2030) (distributed)



Loss of Utility PV

Outage of a converter-based unit, frequency droop support from battery

Derated to 60%

The commercial PVs were derated to 60%, capacity available for reserve

System Details

Scenario: High PV

Total Generation: 193 MW


Total Renewables: 157 MW

Res. PV: 82 MW (no derating)

Comm. PV: 57 MW (60 % derated)

Utility PV: 18 MW (60 % derated)

Battery: 25 MW (Charging)




Bus voltage profiles

System reaches stable state, converter units contributed to fast frequency recovery.



What worked and what can be improved in ETAP!



Our Recommendations

Transient Stability Analysis

- **Component and control parameters info.:** Accurate knowledge of system components needed – generator, lines, transformers
- **Need for validation:** Basic validation for major components and overall system needed to represent actual system behaviour
- **For system reliability, planning future expansions:** With system snapshots for different loading, accurate dynamic models - a contingency analysis can help identify critical assets
- **Developed model of NP and Eleuthera and Exuma Islands** can serve as a template to see how such studies are performed

Model requirements for unit connection

- New converter-based plants should supply **unit and plant models** before interconnection
- For larger units, the **system response should be studied** with and w/o unit

Switch to ETAP v22

- **New features:** Dynamic models for inverters, load scenario in wizard, data manager
- **Grid forming inverters** can now be modelled

Photo Credits



energynautics
solutions for sustainable development

Synchronous generator: smalllike / Noun Project

Battery: Designing Hub / Noun Project

Utility PV: Eliricon / Noun Project

Commercial PV: Cipto Nur Khoir / Noun Project

Residential PV: Laymik / Noun Project

Country Map: Attribution 4.0 International (CC BY 4.0)